

## Utility Conflict Report

<b>OWNER</b>	<b>Utility</b>	CPS	<b>Corridor</b>	SW MILITARY	<b>SITE PHOTOS</b>		
	<b>Contact</b>	BILL FEY	<b>ID</b>	3152			
<b>GENERAL INFO</b>	<b>Utility</b>	GAS					
	<b>Size and Material</b>	STANDARD GAS VALVE, CAST IRON					
	<b>Accessible Route</b>	ASSET IS INSIDE ACCESSIBLE ROUTE					
	<b>Longitudinal or Crossing</b>	CROSSING					
	<b>Placement Relative to ROW</b>	INSIDE ROW					
<b>LOCATION</b>	<b>Sheet No.</b>	143					
	<b>Station</b>	590+82.18					
	<b>Offset</b>	27.42					
	<b>Latitude</b>	+29.356479					
	<b>Longitude</b>	-98.54125					
<b>SUE</b>	<b>Level of Investigation Req'd</b>	NONE					
	<b>Test Hole No</b>	N/A					
	<b>Test Hole Depth</b>	N/A					
<b>RESOLUTION</b>	<b>Recommended Action</b>	MINIMIZE - PROTECT IN PLACE					
	<b>Estimated Resolution Date</b>						
	<b>Resolution Status</b>	UTILITY OWNER INFORMED OF UTILITY					
	<b>Comment</b>	Valve to front of sidewalk = 2'-6" Top of valve to surface = 3'-9 1/2" Lid flange thickness = 3/8" Total lid thickness = 1 7/8"					
<b>Date Collected</b>		7/31/2018 11:14:44 AM		<b>Date Modified</b>		11/28/2018 6:59:12 AM	

