

Utility Conflict Report

OWNER	Utility	SAWS	Corridor	NOGALITOS	SITE PHOTOS
	Contact	ANN PECHE	ID	4074	
GENERAL INFO	Utility	WATER			
	Size and Material	STANDARD WATER METER, STEEL			
	Accessible Route	ASSET IS OUTSIDE ACCESSIBLE ROUTE			
	Longitudinal or Crossing	CROSSING			
	Placement Relative to ROW	INSIDE ROW			
LOCATION	Sheet No.	80			
	Station	126+60.51			
	Offset	36.8588			
	Latitude	+29.391881			
	Longitude	-98.51913			
SUE	Level of Investigation Req'd	NONE			
	Test Hole No	N/A			
	Test Hole Depth	N/A			
RESOLUTION	Recommended Action	NO CONFLICT			
	Estimated Resolution Date				
	Resolution Status	NO RESOLUTION WAS REQUIRED			
	Comment	Top of pipe to surface = 7 1/2" Meter to back of sidewalk = 11" Steel plate lid thickness = 1/2" Lid not labeled			
	Date Collected	7/10/2018 1:52:21 PM	Date Modified	8/15/2018 12:45:54 PM	

