

add cabinet
comments from
meeting and
layouts

TxDOT Utility Conflict Management (UCM) - Utility Conflict List

Project Owner: City of Seguin
 CCSJ/RCSJ.: 0915-45-052
 Project Description: Expand roadway from 2 to 4 lanes with raised median or center turn lane. Realign Cordova at SH 46. Add shared used paths "on both sides."
 Highway or Route: Cordova Rd Between SH 46 and SH 123

Developed/Revised By: Pape-Dawson Engineers
 Date: 8/25/2023
 Reviewed By:
 Date:

Note: Use companion sheet to compare utility conflict resolution alternatives

Utility Company	Utility Company Contact	Utility Conflict ID	Drawing or Sheet No.	Utility Type	Size and/or Material	Utility Conflict Description	Longitudinal or Crossing	Utility Placement in Relation to Existing TxDOT Right of Way	Station Origin	Start Station	Start Offset	End Station	End Offset	Level of Utility Investigation Needed	Test Hole No.	Test Hole Depth	Recommended Action or Resolution	Estimated Resolution Date	Resolution Status	Comments
AT&T	Parish Austin pa2459@att.com	13	2-9	Communications	FO/DUCT	Fiber Optic Cable	Longitudinal	Outside	Cordova Rd	112+70	533' LT	153+95	13' LT	QLB			Accommodate - Relocation		Utility Conflict Created	FOC in conflict with proposed roadway starting at STA 117+00
AT&T	Parish Austin pa2459@att.com	379	2	Communications	Unknown	Telephone line	Longitudinal	Outside	Cordova Rd	113+25	404' LT	113+69	377' LT	QLB			Accommodate - Relocation		Utility Conflict Created	Telephone line conflicts with proposed roadway and row acquisition starting at STA 117+00
AT&T	Parish Austin pa2459@att.com	14	2-9	Communications	Unknown	Telephone line	Longitudinal	Outside	Cordova Rd	113+27	409' LT	153+94	7' LT	QLB			Accommodate - Relocation		Utility Conflict Created	Telephone line conflicts with proposed roadway and row acquisition starting at STA 117+00
AT&T	Parish Austin pa2459@att.com	15	2, 5-9	Communications	Unknown	Telephone line	Crossing	Outside	Cordova Rd	113+69	378' LT	154+88	45' RT	QLB			Accommodate - Relocation		Utility Conflict Created	Telephone line conflicts with proposed roadway and sidewalk
AT&T	Parish Austin pa2459@att.com	23	6	Communications	Unknown	Telephone cabinet	Longitudinal	Outside	Cordova Rd	125+95	27' LT	125+95	27' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone cabinet conflicts with proposed sidewalk, driveway, and row acquisition
AT&T	Parish Austin pa2459@att.com	24	6	Communications	Unknown	Telephone pedestal	Longitudinal	Outside	Cordova Rd	125+97	27' LT	125+97	27' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone pedestal conflictst with proposed roadway
AT&T	Parish Austin pa2459@att.com	25	6-9	Communications	FO/DUCT	Fiber Optic Cable	Longitudinal	Outside	Cordova Rd	125+98	29' LT	154+20	12' LT	QLB			Accommodate - Relocation		Utility Conflict Created	FOC in conflict with proposed roadway
AT&T	Parish Austin pa2459@att.com	39	7	Communications	Unknown	Handhole	Longitudinal	Outside	Cordova Rd	135+04	25' LT	135+04	25' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Fiber handhole in conflict with proposed roadway
AT&T	Parish Austin pa2459@att.com	58	8	Communications	Unknown	Telephone pedestal	Longitudinal	Outside	Cordova Rd	149+28	36' RT	149+28	36' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone pedestal conflictst with proposed driveway
AT&T	Parish Austin pa2459@att.com	63	9	Communications	Unknown	Telephone line	Crossing	Outside	Cordova Rd	153+94	6' LT	157+66	10' RT	QLD			Accommodate - Relocation		Utility Conflict Created	Telephone line conflicts with proposed roadway
AT&T	Parish Austin pa2459@att.com	345	9	Communications	Unknown	Telephone line	Longitudinal	Outside	Cordova Rd	154+21	44' RT	154+26	4' LT	QLD			Accommodate - Relocation		Utility Conflict Created	Telephone line conflicts with proposed roadway
AT&T	Parish Austin pa2459@att.com	62	9	Communications	FO/DUCT	Fiber Optic Cable	Crossing	Outside	Cordova Rd	154+29	1' RT	157+69	14' RT	QLD			Accommodate - Relocation		Utility Conflict Created	FOC in conflict with proposed roadway
AT&T	Parish Austin pa2459@att.com	347	9	Communications	Unknown	Telephone pedestal	Longitudinal	Outside	Cordova Rd	154+75	5' LT	154+75	5' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone pedestal conflictst with proposed roadway
AT&T	Parish Austin pa2459@att.com	348	9	Communications	Unknown	CATV pedestal	Longitudinal	Outside	Cordova Rd	154+87	6' LT	154+87	6' LT	QLC			Accommodate - Relocation		Utility Conflict Created	CATV pedestal conflicts with proposed roadway
AT&T	Parish Austin pa2459@att.com	346	9	Communications	Unknown	Telephone pole	Longitudinal	Outside	Cordova Rd	154+98	5' LT	154+98	5' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone pole conflicts with proposed roadway
AT&T	Parish Austin pa2459@att.com	71	9	Communications	Unknown	Overhead telephone line	Longitudinal	Outside	Cordova Rd	157+34	62' RT	157+74	2' RT	QLC			Accommodate - Relocation		Utility Conflict Created	OHT conflicts with proposed roadway, sidewalk and driveway, and row acquisition
AT&T	Parish Austin pa2459@att.com	73	9	Communications	Unknown	Telephone pole	Longitudinal	Outside	Cordova Rd	157+34	59' RT	157+34	59' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone pole conflicts with proposed roadway, sidewalk and driveway, and row acquisition
AT&T	Parish Austin pa2459@att.com	74	9	Communications	Unknown	Telephone cabinet	Longitudinal	Outside	Cordova Rd	157+59	42' LT	157+59	42' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone cabinet conflicts with row acquisition
AT&T	Parish Austin pa2459@att.com	68	9	Communications	FO/DUCT	Fiber Optic Cable	Longitudinal	Outside	Cordova Rd	157+66	45' LT	159+28	81' LT	QLB			Accommodate - Relocation		Utility Conflict Created	FOC in conflict with proposed sidewalk and row acquisition
AT&T	Parish Austin pa2459@att.com	75	9	Communications	Unknown	CATV cabinet	Longitudinal	Outside	Cordova Rd	157+68	34' LF	157+68	34' LF	QLC			Accommodate - Relocation		Utility Conflict Created	Handhole is in conflict with proposed roadway and row acquisition
AT&T	Parish Austin pa2459@att.com	64	9	Communications	FO/DUCT	Fiber Optic Cable	Crossing	Outside	Cordova Rd	157+75	3' LT	165+42	61' LT	QLD			Accommodate - Relocation		Utility Conflict Created	FOC in conflict with proposed roadway
AT&T	Parish Austin pa2459@att.com	76	9	Communications	Unknown	Handhole	Longitudinal	Outside	Cordova Rd	157+75	26' LT	157+75	26' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Handhole (3) conflicts with proposed roadway
AT&T	Parish Austin pa2459@att.com	380	9-10	Communications	Unknown	Fiber Optic Cable	Longitudinal	Outside	Cordova Rd	157+75	35' LT	164+76	152' LT	QLB			Accommodate - Relocation		Utility Conflict Created	FOC conflicts with proposed, sidewalk, driveway, and row acquisition
AT&T	Parish Austin pa2459@att.com	78	9-10	Communications	Unknown	Telephone line	Crossing	Outside	Cordova Rd	159+17	50' LT	163+89	149' LT	QLB			Accommodate - Relocation		Utility Conflict Created	Telephone line in conflict with removal
AT&T	Parish Austin pa2459@att.com	95	10	Communications	FO/DUCT	Handhole	Longitudinal	Outside	Cordova Rd	164+66	58' RT	164+66	58' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Fiber handhole conflicts with proposed sidewalk and row acquisition
AT&T	Parish Austin pa2459@att.com	94	10	Communications	FO/DUCT	Fiber Optic Cable	Crossing	Outside	Cordova Rd	164+68	58' RT	164+76	54' LT	QLB			Accommodate - Relocation		Utility Conflict Created	FOC in conflict with proposed roadway and sidewalk
AT&T	Parish Austin pa2459@att.com	108	11	Communications	OHT	Overhead electric line	Crossing	Outside	Cordova Rd	165+49	37' RT	165+46	59' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway, sidewalk, and row acquisition
AT&T	Parish Austin pa2459@att.com	2	2	Communications	FO/DUCT	Fiber Optic Cable	Crossing	Outside	SH 46	170+18	75' LT	172+05	77' LT	QLB			Accommodate - Relocation		Utility Conflict Created	FOC in conflict with removal
AT&T	Parish Austin pa2459@att.com	3	2	Communications	Unknown	Telephone line	Crossing	Outside	SH 46	171+36	75' LT	172+05	378' LT	QLB			Accommodate - Relocation		Utility Conflict Created	Telephone line in conflict with removal

inc
3
lik
in
ke

Utility Company	Utility Company Contact	Utility Conflict ID	Drawing or Sheet No.	Utility Type	Size and/or Material	Utility Conflict Description	Longitudinal or Crossing	Utility Placement in Relation to Existing TxDOT Right of Way	Station Origin	Start Station	Start Offset	End Station	End Offset	Level of Utility Investigation Needed	Test Hole No.	Test Hole Depth	Recommended Action or Resolution	Estimated Resolution Date	Resolution Status	Comments
AT&T	Parish Austin pa2459@att.com	128	12-16	Communications	Unknown	Telephone line	Crossing	Outside	Cordova Rd	176+73	19' LT	215+84	128' LT	QLB			Accommodate - Relocation		Utility Conflict Created	Telephone line conflicts with proposed roadway
AT&T	Parish Austin pa2459@att.com	127	12	Communications	Unknown	Handhole	Longitudinal	Outside	Cordova Rd	177+71	54' LT	177+71	54' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Handhole conflicts with proposed sidewalk
AT&T	Parish Austin pa2459@att.com	132	12-19	Communications	Unknown	Telephone line	Crossing	Outside	Cordova Rd	180+11	59' LT	254+08	12' LT	QLB			Accommodate - Relocation		Utility Conflict Created	Telephone line conflicts with proposed sidewalk and driveway
AT&T	Parish Austin pa2459@att.com	137	13	Electric	Unknown	Electric pole	Longitudinal	Outside	Cordova Rd	194+37	39' LT	194+37	39' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Electric pole conflict with row acquisition
AT&T	Parish Austin pa2459@att.com	136	13	Communications	Unknown	Handhole	Longitudinal	Outside	Cordova Rd	194+42	37' LT	194+42	37' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Handhole conflicts with row acquisition
AT&T	Parish Austin pa2459@att.com	358	14	Communications	Unknown	Handhole	Longitudinal	Outside	Cordova Rd	198+60	32' LT	198+60	32' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Handhole conflicts with proposed
AT&T	Parish Austin pa2459@att.com	373	14	Communications	Unknown	Telephone pedestal	Longitudinal	Outside	Cordova Rd	199+44	14' RT	199+44	14' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone pedestal conflicts with row acquisition
AT&T	Parish Austin pa2459@att.com	144	14	Communications	Unknown	Telephone vault	Longitudinal	Outside	Cordova Rd	199+47	37' LT	199+47	37' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone vault conflicts with proposed sidewalk
AT&T	Parish Austin pa2459@att.com	159	14-16	Communications	FO/DUCT	Fiber Optic Cable	Longitudinal	Outside	Cordova Rd	203+68	29' LT	215+94	113' LT	QLB			Accommodate - Relocation		Utility Conflict Created	FOC conflicts with proposed roadway
AT&T	Parish Austin pa2459@att.com	156	14	Communications	Unknown	Handhole	Longitudinal	Outside	Cordova Rd	203+71	24' RT	203+71	24' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Handhole conflicts with row acquisition
AT&T	Parish Austin pa2459@att.com	155	14	Communications	Unknown	Telephone cabinet	Longitudinal	Outside	Cordova Rd	203+76	36' RT	203+76	36' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone cabinet conflicts with row acquisition
AT&T	Parish Austin pa2459@att.com	165	15	Communications	Unknown	Telephone pedestal	Longitudinal	Outside	Cordova Rd	209+53	34' LT	209+53	34' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone vault conflicts with row acquisition
AT&T	Parish Austin pa2459@att.com	359	16	Communications	FO/DUCT	Fiber Optic Cable	Crossing	Outside	Cordova Rd	215+27	35' RT	215+31	126' LT	QLB			Accommodate - Relocation		Utility Conflict Created	FOC conflicts with proposed, sidewalk, driveway, and row acquisition
AT&T	Parish Austin pa2459@att.com	178	16	Communications	Unknown	Telephone pedestal	Crossing	Outside	Cordova Rd	215+76	13' RT	215+76	13' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone pedestal conflicts with proposed roadway
AT&T	Parish Austin pa2459@att.com	177	16-23	Communications	Unknown	Telephone line	Longitudinal	Outside	Cordova Rd	215+77	29' LT	294+38	69' RT	QLB			Accommodate - Relocation		Utility Conflict Created	Telephone line conflicts with proposed roadway
AT&T	Parish Austin pa2459@att.com	180	16	Communications	Unknown	Handhole	Longitudinal	Outside	Cordova Rd	216+13	45' LT	216+13	45' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Handhole conflicts with proposed sidewalk
AT&T	Parish Austin pa2459@att.com	189	17	Communications	Unknown	Handhole	Longitudinal	Outside	Cordova Rd	225+53	55' LT	225+53	55' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Handhole conflicts with proposed sidewalk
AT&T	Parish Austin pa2459@att.com	218	18	Communications	Unknown	Handhole	Longitudinal	Outside	Cordova Rd	242+04	22' LT	242+04	22' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Handhole conflicts with proposed roadway
AT&T	Parish Austin pa2459@att.com	232	18-26	Communications	FO/DUCT	Fiber Optic Cable	Longitudinal	Outside	Cordova Rd	243+94	71' RT	294+37	71' RT	QLB			Accommodate - Relocation		Utility Conflict Created	FOC conflicts with proposed, sidewalk, driveway, and row acquisition
AT&T	Parish Austin pa2459@att.com	224	18-20	Communications	Unknown	CTV	Longitudinal	Outside	Cordova Rd	244+09	32' LT	258+98	32' LT	QLD			Accommodate - Relocation		Utility Conflict Created	CTV conflicts with proposed roadway and sidewalk
AT&T	Parish Austin pa2459@att.com	227	19	Communications	Unknown	Handhole	Longitudinal	Outside	Cordova Rd	248+53	24' LT	248+53	24' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Handhole conflicts with proposed roadway
AT&T	Parish Austin pa2459@att.com	238	19	Communications	Unknown	Telephone pole	Longitudinal	Outside	Cordova Rd	253+22	27' LT	253+22	27' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone pole conflicts with proposed roadway
AT&T	Parish Austin pa2459@att.com	239	19	Communications	Unknown	Telephone pedestal	Longitudinal	Outside	Cordova Rd	254+24	25' LT	254+24	25' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone pedestal conflicts with proposed roadway
AT&T	Parish Austin pa2459@att.com	249	20	Communications	Unknown	Telephone pedestal	Longitudinal	Outside	Cordova Rd	258+97	29' LT	258+97	29' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone pedestal conflicts with proposed roadway
AT&T	Parish Austin pa2459@att.com	250	20	Communications	Unknown	Handhole	Longitudinal	Outside	Cordova Rd	259+08	26' LT	259+08	26' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Handhole conflicts with proposed roadway
AT&T	Parish Austin pa2459@att.com	260	20-22	Communications	Unknown	Telephone line	Longitudinal	Outside	Cordova Rd	261+57	37' LT	273+68	276' LT	QLB			Accommodate - Relocation		Utility Conflict Created	Telephone line conflicts with proposed roadway and sidewalk
AT&T	Parish Austin pa2459@att.com	263	21	Communications	Unknown	Telephone pedestal	Longitudinal	Outside	Cordova Rd	266+03	56' LT	266+03	56' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone pedestal conflicts with proposed roadway realignment
AT&T	Parish Austin pa2459@att.com	279	22	Communications	Unknown	Telephone pedestal	Longitudinal	Outside	Cordova Rd	273+66	272' LT	273+66	272' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone pedestal conflicts with proposed roadway realignment
AT&T	Parish Austin pa2459@att.com	281	22	Communications	Unknown	Telephone manhole	Longitudinal	Outside	Cordova Rd	274+17	236' LT	274+17	236' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone manhole conflicts with proposed roadway and roadway realignment
AT&T	Parish Austin pa2459@att.com	282	23	Communications	Unknown	Handhole	Longitudinal	Outside	Cordova Rd	276+36	436' LT	276+36	436' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Handhole conflicts with proposed roadway and roadway realignment
AT&T	Parish Austin pa2459@att.com	292	23	Communications	Unknown	Telephone pedestal	Longitudinal	Outside	Cordova Rd	280+27	566' LT	280+27	566' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone pedestal conflicts with proposed roadway realignment
AT&T	Parish Austin pa2459@att.com	301	24	Communications	Unknown	Telephone pedestal	Longitudinal	Outside	Cordova Rd	282+33	575' LT	282+33	575' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone pedestal conflicts with proposed roadway realignment
AT&T	Parish Austin pa2459@att.com	302	24	Communications	Unknown	Handhole	Longitudinal	Outside	Cordova Rd	282+53	562' LT	282+53	562' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone handhole conflicts with proposed roadway realignment
AT&T	Parish Austin pa2459@att.com	312	24	Communications	Unknown	Telephone pedestal	Longitudinal	Outside	Cordova Rd	283+90	455' LT	283+90	455' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone pedestal conflicts with proposed roadway realignment
AT&T	Parish Austin pa2459@att.com	331	26	Communications	Unknown	Handhole	Longitudinal	Outside	Cordova Rd	293+15	28' LT	293+15	28' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Handhole conflicts with proposed roadway
AT&T	Parish Austin pa2459@att.com	329	26	Communications	Unknown	Telephone pedestal	Longitudinal	Outside	Cordova Rd	293+32	23' LT	293+32	23' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Telephone pedestal conflicts with proposed roadway

Utility Company	Utility Company Contact	Utility Conflict ID	Drawing or Sheet No.	Utility Type	Size and/or Material	Utility Conflict Description	Longitudinal or Crossing	Utility Placement in Relation to Existing TxDOT Right of Way	Station Origin	Start Station	Start Offset	End Station	End Offset	Level of Utility Investigation Needed	Test Hole No.	Test Hole Depth	Recommended Action or Resolution	Estimated Resolution Date	Resolution Status	Comments
AT&T	Parish Austin pa2459@att.com	339	26	Communications	FO/DUCT	Fiber Optic Cable	Crossing	Outside	Cordova Rd	294+46	60' RT	294+49	63' LT	QLD			Accommodate - Relocation		Utility Conflict Created	FOC does not have a direct conflict, but it could pose an issue with other conflicts
Brightspeed	Charles Brown joel.garay@brightspeed.com	175	16	Communications	FO/DUCT	Fiber Optic Cable	Crossing	Outside	Cordova Rd	215+31	35' RT	215+38	127' LT	QLB			Accommodate - Relocation		Utility Conflict Created	FOC does not have a direct conflict, but it could pose an issue with other conflicts
Brightspeed	Charles Brown joel.garay@brightspeed.com	338	26	Communications	FO/DUCT	Fiber Optic Cable	Crossing	Outside	Cordova Rd	294+33	57' RT	294+44	71' LT	QLD			Accommodate - Relocation		Utility Conflict Created	FOC does not have a direct conflict, but it could pose an issue with other conflicts
CenterPoint Energy	Fernando Ruelas-Valtierra fernando.ruelasvaltierra@centerpointenergy.com	222	18-24	Gas	Unknown	Pipeline	Longitudinal	Outside	Cordova Rd	243+75	52' LT	285+53	376' LT	QLB			Accommodate - Relocation		Utility Conflict Created	Pipeline conflicts with proposed roadway
City of Seguin	Clarence Smith csmith@seguintexas.gov	6	2	Sanitary Sewer	Unknown	Waste waster line	Crossing	Outside	SH 46	173+53	100 LT	170+28	118 LT	QLB			Accommodate - Relocation		Utility Conflict Created	Waste water line in conflict with removal
City of Seguin	Clarence Smith csmith@seguintexas.gov	216	18	Sanitary Sewer	Unknown	Waste waster line	Longitudinal	Outside	Cordova Rd	244+45	26' RT	244+98	53' RT	QLB			Accommodate - Relocation		Utility Conflict Created	Waste water line conflicts with proposed roadway and sidewalk
City of Seguin	Clarence Smith csmith@seguintexas.gov	233	19	Sanitary Sewer	Unknown	Waste waster line	Longitudinal	Outside	Cordova Rd	247+81	52' RT	248+46	51' RT	QLB			Accommodate - Relocation		Utility Conflict Created	Waste water lines and manholes conflicts with proposed roadway and sidewalk, and row acquisition
City of Seguin	Clarence Smith csmith@seguintexas.gov	217	19	Sanitary Sewer	Unknown	Waste waster line	Longitudinal	Outside	Cordova Rd	248+25	61' RT	248+59	61' RT	QLB			Accommodate - Relocation		Utility Conflict Created	Waste water line and manhole conflicts with proposed roadway
City of Seguin	Clarence Smith csmith@seguintexas.gov	380	19	Sanitary Sewer	Unknown	Waste waster line	Crossing	Outside	Cordova Rd	248+58	27' RT	248+58	95' RT	QLB			Accommodate - Relocation		Utility Conflict Created	Waste water lines and manholes conflicts with proposed roadway
City of Seguin	Clarence Smith csmith@seguintexas.gov	326	26	Water	Unknown	Waste waster line	Crossing	Outside	Cordova Rd	294+06	65' LT	294+01	71' RT	QLB			Accommodate - Relocation		Utility Conflict Created	Waste water line conflicts with proposed roadway and sidewalk. This conflict consists of 3 consecutive parallel waste water lines.
CPS Energy	Jennifer Henriquez 210-314-9708 jhenriquez@cpsenergy.com	383	19	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	253+66	72' LT	253+69	42' RT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE and power pole conflict with proposed roadway and sidewalk, and row acquisition
Exxon Mobil Pipeline	Antonio Alaniz antonio.alaniz@exxonmobil.com	153	14	Oil	10" Casing	Pipeline	Crossing	Outside	Cordova Rd	203+27	10' RT	203+47	46' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Pipeline conflicts with proposed roadway. The depth is 6' on the south side of Cordova and 6'3" on the northside. The pipeline has a 10" casing.
GVEC	Travis Engler tengler@gvec.org	22	6	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	126+01	30' LT	126+02	90' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway improvements, row acquisition, and proposed sidewalk.
GVEC	Travis Engler tengler@gvec.org	46	7	Electric	OHE	Overhead electric line	Longitudinal	Outside	Cordova Rd	131+48	39' RT	131+60	29' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway
GVEC	Travis Engler tengler@gvec.org	40	7	Electric	OHE	Overhead electric line	Longitudinal	Outside	Cordova Rd	138+33	82' LT	138+33	30' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway
GVEC	Travis Engler tengler@gvec.org	55	8	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	147+50	47' RT	147+93	26' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway
GVEC	Travis Engler tengler@gvec.org	59	9	Electric	OHE	Overhead electric line	Longitudinal	Outside	Cordova Rd	152+76	59' LT	153+11	22' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway, row acquisition, and proposed sidewalk.
GVEC	Travis Engler tengler@gvec.org	60	9	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	154+24	49' RT	154+98	8' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway improvements and sidewalk.
GVEC	Travis Engler tengler@gvec.org	67	9-24	Electric	OHE	Overhead electric line	Longitudinal	Outside	Cordova Rd	154+98	8' LT	280+15	569' LT	QLD			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway improvements, row acquisition, and proposed sidewalk.
GVEC	Travis Engler tengler@gvec.org	72	9	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	157+43	87' RT	157+74	2' RT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway, sidewalk and driveway, and row acquisition
GVEC	Travis Engler tengler@gvec.org	77	9	Electric	UGE	Underground electric line	Longitudinal	Outside	Cordova Rd	157+66	37' LT	159+97	55' LT	QLB			Accommodate - Relocation		Utility Conflict Created	Underground electric line conflicts with row acquisition, proposed sidewalk, and driveway. GVEC likes to keep underground in easement.
GVEC	Travis Engler tengler@gvec.org	79	9	Electric	Unknown	Light pole	longitudinal	Outside	Cordova Rd	159+96	71' LT	159+96	71' LT				Accommodate - Relocation		Utility Conflict Created	Light pole conflicts with proposed roadway
GVEC	Travis Engler tengler@gvec.org	354	10	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	160+79	22' LT	160+86	55' RT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway, sidewalk, driveway, and row acquisition
GVEC	Travis Engler tengler@gvec.org	83	10	Electric	Unknown	Water valve	Longitudinal	Outside	Cordova Rd	161+05	57' LT	161+05	57' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water valve (4) conflicts with row acquisition
GVEC	Travis Engler tengler@gvec.org	91	10	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	163+14	87' LT	163+52	22' RT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway, sidewalk, driveway, and row acquisition
GVEC	Travis Engler tengler@gvec.org	92	10	Electric	Unknown	Handhole	Longitudinal	Outside	Cordova Rd	163+49	24' RT	163+49	24' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Handhole is in conflict with row acquisition
GVEC	Travis Engler tengler@gvec.org	93	10	Electric	Unknown	Electric pole	Longitudinal	Outside	Cordova Rd	163+51	22' RT	163+51	22' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Electric pole is in conflict with row acquisition

Utility Company	Utility Company Contact	Utility Conflict ID	Drawing or Sheet No.	Utility Type	Size and/or Material	Utility Conflict Description	Longitudinal or Crossing	Utility Placement in Relation to Existing TxDOT Right of Way	Station Origin	Start Station	Start Offset	End Station	End Offset	Level of Utility Investigation Needed	Test Hole No.	Test Hole Depth	Recommended Action or Resolution	Estimated Resolution Date	Resolution Status	Comments
GVEC	Travis Engler tengler@gvec.org	370	10	Electric	UGE	Underground electric line	Longitudinal	Outside	Cordova Rd	163+53	25' RT	164+01	25' RT	QLB			Accommodate - Relocation		Utility Conflict Created	Underground electric line conflicts with proposed roadway
GVEC	Travis Engler tengler@gvec.org	97	10	Electric	Unknown	Light pole	Longitudinal	Outside	Cordova Rd	164+04	22' RT	164+04	22' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Light pole conflicts with proposed roadway
GVEC	Travis Engler tengler@gvec.org	109	11	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	165+48	61' LT	165+50	41' RT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway and row acquisition
GVEC	Travis Engler tengler@gvec.org	1	2	Electric	OHE	Overhead electric line	Crossing	Inside	SH 46	170+76	75' LT	173+59	58' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Existing power pole in conflict with removal
GVEC	Travis Engler tengler@gvec.org	11	2-24	Electric	OHE	Overhead electric line	Longitudinal	Outside	SH 46	172+03	55' LT	280+09	569' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway improvements, row acquisition, and proposed sidewalk starting at STA 117+00
GVEC	Travis Engler tengler@gvec.org	118	12	Electric	OHE	Overhead electric line	Longitudinal	Outside	Cordova Rd	176+89	60' LT	177+00	96' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed sidewalk and row acquisition
GVEC	Travis Engler tengler@gvec.org	125	12	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	183+46	119' LT	183+46	60' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed sidewalk and row acquisition
GVEC	Travis Engler tengler@gvec.org	126	12	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	184+97	58' LT	184+98	103' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed sidewalk and row acquisition
GVEC	Travis Engler tengler@gvec.org	143	14	Electric	OHE	Overhead electric line	Longitudinal	Outside	Cordova Rd	199+41	65' LT	199+47	40' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed sidewalk and row acquisition
GVEC	Travis Engler tengler@gvec.org	151	14	Electric	OHE	Overhead electric line	Longitudinal	Outside	Cordova Rd	202+72	66' LT	202+79	41' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway and sidewalk, and row acquisition
GVEC	Travis Engler tengler@gvec.org	154	14	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	203+81	26' RT	204+42	41' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway
GVEC	Travis Engler tengler@gvec.org	164	15	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	205+99	18' RT	206+00	40' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway
GVEC	Travis Engler tengler@gvec.org	181	16	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	216+10	8' RT	216+03	117' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway, sidewalk, driveway, and row acquisition
GVEC	Travis Engler tengler@gvec.org	190	17	Electric	Unknown	Electric pole	Longitudinal	Outside	Cordova Rd	226+50	56' LT	226+50	56' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Electric pole conflicts with proposed sidewalk
GVEC	Travis Engler tengler@gvec.org	193	17	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	230+36	46' LT	230+41	51' RT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway, sidewalk, driveway, and row acquisition
GVEC	Travis Engler tengler@gvec.org	198	17	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	233+76	23' LT	233+84	67' RT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway, sidewalk, driveway, and row acquisition. Major crossing
GVEC	Travis Engler tengler@gvec.org	226	19	Electric	Unknown	Electric pole	Longitudinal	Outside	Cordova Rd	248+56	26' LT	248+56	26' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Electric pole conflicts with proposed roadway
GVEC	Travis Engler tengler@gvec.org	241	19-20	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	252+98	28' LT	253+03	69' RT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway and sidewalk, and row acquisition. Major crossing.
GVEC	Travis Engler tengler@gvec.org	244	19-20	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	254+68	60' RT	254+98	59' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway and sidewalk, and row acquisition
GVEC	Travis Engler tengler@gvec.org	256	20	Electric	Unknown	Electric pole	Longitudinal	Outside	Cordova Rd	259+01	29' LT	259+01	29' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Electric pole conflicts with proposed roadway
GVEC	Travis Engler tengler@gvec.org	277	22	Electric	Unknown	Electric pole	Longitudinal	Outside	Cordova Rd	273+16	262' LT	273+16	262' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Electric pole does not have a direct conflict, but it could pose an issue with other conflicts
GVEC	Travis Engler tengler@gvec.org	278	22	Electric	Unknown	Handhole	Longitudinal	Outside	Cordova Rd	273+20	264' LT	273+20	264' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Electric handhole does not have a direct conflict, but it could pose an issue with other conflicts
GVEC	Travis Engler tengler@gvec.org	280	22-26	Electric	UGE	Underground electric line	Crossing	Outside	Cordova Rd	273+57	269' LT	294+16	74' RT	QLB			Accommodate - Relocation		Utility Conflict Created	Underground electric line and manhole conflict with proposed roadway and roadway realignment. Includes 3 circuit feeds going east and 2 large underground conductors going west. Vault located at beginning of southern portion of this conflict. On p. 26, 12 pipes with electric, large, 3 feeders, major circuit
GVEC	Travis Engler tengler@gvec.org	288	23	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	280+15	569' LT	281+63	616' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE does not have a direct conflict, but it could pose an issue with other conflicts
GVEC	Travis Engler tengler@gvec.org	304	24	Electric	Unknown	Cabinet	Longitudinal	Outside	Cordova Rd	280+91	269' LT	280+91	269' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Electric cabinet does not have a direct conflict, but it could pose an issue with other conflicts
GVEC	Travis Engler tengler@gvec.org	311	24	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	281+95	208' LT	283+05	306' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE does not have a direct conflict, but it could pose an issue with other conflicts

Utility Company	Utility Company Contact	Utility Conflict ID	Drawing or Sheet No.	Utility Type	Size and/or Material	Utility Conflict Description	Longitudinal or Crossing	Utility Placement in Relation to Existing TxDOT Right of Way	Station Origin	Start Station	Start Offset	End Station	End Offset	Level of Utility Investigation Needed	Test Hole No.	Test Hole Depth	Recommended Action or Resolution	Estimated Resolution Date	Resolution Status	Comments
GVEC	Travis Engler tengler@gvec.org	306	24-26	Electric	UGE	Underground electric line	Longitudinal	Outside	Cordova Rd	282+32	567' LT	293+89	61' LT	QLB			Accommodate - Relocation		Utility Conflict Created	Underground electric line does not have a direct conflict, but it could pose an issue with other conflicts. Includes FOC.
GVEC	Travis Engler tengler@gvec.org	361	24	Electric	UGE	Underground electric line	Longitudinal	Outside	Cordova Rd	286+19	457' LT	286+44	386' LT	QLB			Accommodate - Relocation		Utility Conflict Created	Underground electric line conflicts with roadway realignment
GVEC	Travis Engler tengler@gvec.org	330	26	Electric	UGE	Underground electric line	Crossing	Outside	Cordova Rd	293+06	28' RT	293+17	62' LT	QLB			Accommodate - Relocation		Utility Conflict Created	Underground electric line conflicts with proposed roadway and sidewalk. Vault, major impact, in private easement today. Very expensive project (\$1 mill roughly 2-5 years ago not including fiber). No vault on the north side of prop Cordova Rd. 3 electric pipes and 1 FOC.
GVEC	Travis Engler tengler@gvec.org	384	1	Electric	Unknown	Electric pole	Longitudinal	Inside	SH 46	166+37	82' RT	166+57	82' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Electric pole conflicts with proposed roadway (2 EA)
GVEC	Travis Engler tengler@gvec.org	368	7	Electric	OHE	Overhead electric line	Crossing	Outside	Cordova Rd	135+06	100' LT	135+10	30' LT	QLC			Accommodate - Relocation		Utility Conflict Created	OHE conflicts with proposed roadway
Markwest	Merry Jayne Stiger mstiger@marathonpetroleum	255	20-21	Oil	Unknown	Pipeline	Crossing	Outside	Cordova Rd	259+38	35' RT	260+34	39' LT	QLB			Accommodate - Relocation		Utility Conflict Created	Pipeline conflicts with proposed roadway
Spectrum	Joel Gonzales joel.gonzales@charter.com	70	9-10	Communications	Unknown	CTV	Crossing	Outside	Cordova Rd	159+88	85' LT	160+80	23' LT	QLD			Accommodate - Relocation		Utility Conflict Created	CTV conflicts with proposed sidewalk and row acquisition
Spectrum	Joel Gonzales joel.gonzales@charter.com	56	10-11	Communications	FO/DUCT	Fiber Optic Cable	Longitudinal	Outside	Cordova Rd	164+54	151' LT	165+44	61' LT	QLD			Accommodate - Relocation		Utility Conflict Created	FOC in conflict with proposed roadway
Spectrum	Joel Gonzales joel.gonzales@charter.com	179	16	Communications	Unknown	CTV	Longitudinal	Outside	Cordova Rd	222+77	58' LT	223+16	128' LT	QLD			Accommodate - Relocation		Utility Conflict Created	CTV conflicts with proposed sidewalk and row acquisition
Spectrum	Joel Gonzales joel.gonzales@charter.com	200	18	Communications	Unknown	CTV	Crossing	Outside	Cordova Rd	235+22	55' LT	235+23	24' LT	QLD			Accommodate - Relocation		Utility Conflict Created	CTV conflicts with proposed sidewalk and roadway
Spectrum	Joel Gonzales joel.gonzales@charter.com	205	18	Communications	Unknown	CTV	Crossing	Outside	Cordova Rd	236+88	56' LT	236+89	24' LT	QLD			Accommodate - Relocation		Utility Conflict Created	CTV conflicts with proposed sidewalk and roadway
Spectrum	Joel Gonzales joel.gonzales@charter.com	361	19	Communications	FO/DUCT	Fiber Optic Cable	Crossing	Outside	Cordova Rd	248+20	52' RT	248+55	28' LT	QLB			Accommodate - Relocation		Utility Conflict Created	FOC conflicts with proposed roadway, sidewalk, and driveway
Spectrum	Joel Gonzales joel.gonzales@charter.com	251	20-26	Communications	FO/DUCT	Fiber Optic Cable	Longitudinal	Outside	Cordova Rd	257+34	30' LT	293+09	23' LT	QLB			Accommodate - Relocation		Utility Conflict Created	FOC conflicts with proposed roadway
Spectrum	Joel Gonzales joel.gonzales@charter.com	337	26	Communications	Unknown	CATV cabinet	Longitudinal	Outside	Cordova Rd	293+38	27' RT	293+38	27' RT	QLC			Accommodate - Relocation		Utility Conflict Created	CATV cabinet conflicts with proposed roadway
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	12	2-26	Water	Unknown	Water line	Longitudinal	Outside	Cordova Rd	112+58	520' RT	293+15	40' LT	QLD			Accommodate - Relocation		Utility Conflict Created	Water line conflicts with proposed roadway, row acquisition, and proposed sidewalk.
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	16	2-6	Water	Unknown	Water line	Longitudinal	Outside	Cordova Rd	113+24	367' RT	121+39	14' RT	QLD			Accommodate - Relocation		Utility Conflict Created	Water line conflicts with proposed roadway
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	19	6	Water	Unknown	Water valve	Longitudinal	Outside	Cordova Rd	125+45	33' LT	125+45	33' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water valve conflicts with proposed roadway improvements and row acquisition
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	21	6	Water	Unknown	Water meter	Longitudinal	Outside	Cordova Rd	125+88	38' LT	125+88	38' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water meter (3) conflicts with proposed roadway improvements. ROW acquisition conflict.
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	48	7	Water	Unknown	Water meter	Longitudinal	Outside	Cordova Rd	132+09	35' LT	132+09	35' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water meter conflicts with proposed roadway improvements, row acquisition and driveway construction
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	37	6	Water	Unknown	Water meter	Longitudinal	Outside	Cordova Rd	132+13	41' RT	132+13	41' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Water meter conflicts with proposed roadway improvements, row acquisition and driveway construction
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	48	7	Water	Unknown	Water valve	Longitudinal	Outside	Cordova Rd	135+55	32' LT	135+55	32' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water vault conflicts with proposed roadway and row acquisition.
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	57	8	Water	Unknown	Water meter	Longitudinal	Outside	Cordova Rd	148+98	39 RT	149+19	39' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Water meter (2) conflicts with proposed roadway improvements, row acquisition and driveway construction
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	61	9	Water	Unknown	Water meter	Longitudinal	Outside	Cordova Rd	153+28	23' LT	153+28	23' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water meter conflicts with proposed roadway improvements, row acquisition and driveway construction
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	9	382	Water	Unknown	Water meter	Longitudinal	Outside	Cordova Rd	154+73	56' LT	154+73	56' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water meter (2) conflicts with proposed roadway improvements. ROW acquisition conflict.
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	69	9	Water	Unknown	Water meter	Longitudinal	Outside	Cordova Rd	155+41	54' RT	156+31	59' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Water meter (3) conflicts with proposed sidewalk improvements and row acquisition
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	381	9	Water	Unknown	Water meter	Longitudinal	Outside	Cordova Rd	158+89	62' RT	159+20	59' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water meter (2) conflicts with proposed sidewalk

Utility Company	Utility Company Contact	Utility Conflict ID	Drawing or Sheet No.	Utility Type	Size and/or Material	Utility Conflict Description	Longitudinal or Crossing	Utility Placement in Relation to Existing TxDOT Right of Way	Station Origin	Start Station	Start Offset	End Station	End Offset	Level of Utility Investigation Needed	Test Hole No.	Test Hole Depth	Recommended Action or Resolution	Estimated Resolution Date	Resolution Status	Comments
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	352	9	Water	Unknown	Water line	Crossing	Outside	Cordova Rd	159+35	72' LT	159+40	8' LT	QLD			Accommodate - Relocation		Utility Conflict Created	Water line conflicts with proposed roadway, row acquisition, and proposed sidewalk.
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	84	10	Water	Unknown	Fire hydrant	Longitudinal	Outside	Cordova Rd	160+08	63' LT	160+08	63' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Fire hydrant conflicts with row acquisition
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	83	10	Water	Unknown	Water valve	Longitudinal	Outside	Cordova Rd	160+98	58' LT	161+17	63' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water valves (4) conflict with row acquisition
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	89	10	Water	Unknown	Water meter	Longitudinal	Outside	Cordova Rd	163+11	12' RT	163+11	12' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Water meter conflicts with proposed roadway
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	98	10	Water	Unknown	Water valve	Longitudinal	Outside	Cordova Rd	164+65	28' RT	164+65	28' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Water valve conflict with proposed roadway
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	99	10	Water	Unknown	Fire hydrant	Longitudinal	Outside	Cordova Rd	164+68	31' RT	164+68	31' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Fire hydrant conflict with proposed roadway
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	355	11	Water	Unknown	Water meter	Longitudinal	Outside	Cordova Rd	165+23	0'	165+32	0'	QLC			Accommodate - Relocation		Utility Conflict Created	Water meter (2) conflicts with proposed roadway
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	356	11-16	Water	Unknown	Water line	Longitudinal	Outside	Cordova Rd	169+47	68' LT	183+38	52' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water line conflict with proposed roadway and sidewalk
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	4	2	Water	Unknown	Water line	Longitudinal	Outside	Cordova Rd	171+24	165' LT	170+20	84' LT	QLD			Accommodate - Relocation		Utility Conflict Created	Water line in conflict with removal
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	357	12-16	Water	Unknown	Water line	Crossing	Outside	Cordova Rd	183+38	52' LT	215+96	129' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water line in conflict with proposed roadway and sidewalk
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	371	13	Electric	Unknown	Water meter	Longitudinal	Outside	Cordova Rd	185+37	67' LT	185+37	67' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water meter conflict with row acquisition
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	148	14	Water	Unknown	Water meter	Longitudinal	Outside	Cordova Rd	200+18	48' LT	200+18	48' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water meter (2) conflicts with row acquisition.
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	149	14	Water	Unknown	Water valve	Longitudinal	Outside	Cordova Rd	200+27	48' LT	200+27	48' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water valve (2) conflicts with row acquisition.
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	150	14	Water	Unknown	Fire hydrant	Longitudinal	Outside	Cordova Rd	200+30	43' LT	200+30	43' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Fire hydrant conflicts with row acquisition
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	168	15	Water	Unknown	Water meter	Longitudinal	Outside	Cordova Rd	205+38	20' RT	205+38	20' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Water meter conflicts with proposed roadway
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	169	16	Water	Unknown	Water valve	Longitudinal	Outside	Cordova Rd	215+15	61' LT	215+15	61' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water valve (5) conflicts with row acquisition.
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	170	16	Water	Unknown	Fire hydrant	Longitudinal	Outside	Cordova Rd	215+19	57' LT	215+19	57' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Fire hydrant conflicts with proposed roadway
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	192	17	Water	Unknown	Water meter	Longitudinal	Outside	Cordova Rd	230+47	9' RT	230+47	9' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Water meter conflicts with proposed roadway
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	207	18	Water	Unknown	Water valve	Longitudinal	Outside	Cordova Rd	238+31	37' LT	238+31	37' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water valve (3) conflicts with row acquisition.
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	160	19	Water	Unknown	Water meter	Longitudinal	Outside	Cordova Rd	248+29	56' RT	248+29	56' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Water meter conflicts with proposed roadway
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	235	19	Water	Unknown	Fire hydrant	Longitudinal	Outside	Cordova Rd	248+31	64' RT	248+31	64' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Fire hydrant conflicts with proposed driveway
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	236	19	Water	Unknown	Water valve	Longitudinal	Outside	Cordova Rd	248+34	64' RT	248+34	64' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Water valve conflicts with row acquisition
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	229	19	Water	Unknown	Water valve	Longitudinal	Outside	Cordova Rd	248+36	34' LT	248+36	34' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water valve (2) conflicts with row acquisition.
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	228	19	Water	Unknown	Fire hydrant	Longitudinal	Outside	Cordova Rd	248+45	33' LT	248+45	33' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Fire hydrant conflicts with proposed roadway and driveway
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	290	23	Water	Unknown	Water valve	Longitudinal	Outside	Cordova Rd	280+04	575' LT	280+04	575' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water valve does not have a direct conflict, but it could pose an issue with other conflicts
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	291	23	Water	Unknown	Fire hydrant	Longitudinal	Outside	Cordova Rd	280+04	575' LT	279+60	576' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Fire hydrant does not have a direct conflict, but it could pose an issue with other conflicts
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	289	23	Water	Unknown	Water meter	Longitudinal	Outside	Cordova Rd	280+12	576' LT	280+12	576' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water meter (2) does not have a direct conflict, but it could pose an issue with other conflicts.
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	303	24	Water	Unknown	Water meter	Longitudinal	Outside	Cordova Rd	281+00	277' LT	281+00	277' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water meter does not have a direct conflict, but it could pose an issue with other conflicts
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	328	26	Water	Unknown	Water valve	Longitudinal	Outside	Cordova Rd	293+48	35' LT	293+48	35' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Water valve conflicts with proposed roadway
Springs Hill Water Supply Co	Devan Montoya dmontoya@springshill.org	327	26	Water	Unknown	Fire hydrant	Longitudinal	Outside	Cordova Rd	293+81	39' LT	293+81	39' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Fire hydrant conflicts with proposed roadway
TxDOT	Pablo Martinez pmartinez@seguintexas.gov	7	2	Electric	Unknown	Signal pole	Longitudinal	Inside	Cordova Rd	112+51	494' LT	112+51	494' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Signal pole is in conflict with proposed roadway improvements
TxDOT	Pablo Martinez pmartinez@seguintexas.gov	8	2	Electric	Handhole	Handhole	Longitudinal	Inside	Cordova Rd	112+53	488' LT	112+53	488' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Handhole is in conflict with proposed roadway improvements
TxDOT	Pablo Martinez pmartinez@seguintexas.gov	9	2	Electric	Unknown	Cabinet	Longitudinal	Inside	Cordova Rd	112+76	483' LT	112+76	483' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Cabinet is in conflict with proposed roadway improvements
TxDOT	Pablo Martinez pmartinez@seguintexas.gov	325	26	Electric	Unknown	Signal handhole	Longitudinal	Inside	Cordova Rd	294+42	26' LT	294+42	26' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Signal handhole conflictst with proposed roadway
TxDOT	Pablo Martinez pmartinez@seguintexas.gov	324	26	Electric	Unknown	Signal pole	Longitudinal	Inside	Cordova Rd	294+44	30' LT	294+44	30' LT	QLC			Accommodate - Relocation		Utility Conflict Created	Signal pole conflictst with proposed roadway

Utility Company	Utility Company Contact	Utility Conflict ID	Drawing or Sheet No.	Utility Type	Size and/or Material	Utility Conflict Description	Longitudinal or Crossing	Utility Placement in Relation to Existing TxDOT Right of Way	Station Origin	Start Station	Start Offset	End Station	End Offset	Level of Utility Investigation Needed	Test Hole No.	Test Hole Depth	Recommended Action or Resolution	Estimated Resolution Date	Resolution Status	Comments
TxDOT	Pablo Martinez pmartinez@seguintexas.gov	340	26	Electric	Unknown	Handhole	Longitudinal	Outside	Cordova Rd	294+48	58' RT	294+48	58' RT	QLC			Accommodate - Relocation		Utility Conflict Created	Electric handhole conflicts with proposed roadway
TxDOT	Pablo Martinez pmartinez@seguintexas.gov	382	26	Electric	UGE	Underground electric line	Crossing	Inside	Cordova Rd	294+51	59' RT	294+43	33' LT	QLB			Accommodate - Relocation		Utility Conflict Created	Underground electric conflicts with roadway improvement
Zayo	John Coughlin 620-899-6671 john.coughlin@zayo.com	141	13-14	Communications	FO/DUCT	Fiber Optic Cable	Longitudinal	Outside	Cordova Rd	194+38	39' LT	201+13	42' LT	QLB			Accommodate - Relocation		Utility Conflict Created	FOC conflicts with proposed driveway and row acquisition
Zayo	John Coughlin 620-899-6671 john.coughlin@zayo.com	252	20-26	Communications	FO/DUCT	Fiber Optic Cable	Crossing	Outside	Cordova Rd	259+00	32' LT	293+18	56' LT	QLB			Accommodate - Relocation		Utility Conflict Created	FOC conflicts with proposed roadway